

The results of the laboratory testing CTM 202, CTM 217, and CTM 301 are presented in Table 2.

**TABLE 2
LABORATORY TEST RESULTS**

STOCKPILE LOCATION	PASSING #200 (%)	SE	R-VALUE	USCS
SE Corner	29	14	53	SM
Olive, 50' W/O Fowler, Left Turn Lane	23	24	-	SM
Olive, 50' E/O Fowler, WB Lane	29	20	-	SM
Fowler, 50' N/O Olive, NB Lane	34	20	-	SM
Fowler, 50' S/O Olive, NB Lane	28	19	-	SM

SM: Silty Sand

Disclaimer:

This information is for the contractor's information only. This is not to be considered to be part of the contract documents and shall have no bearing whatsoever on the interpretation of the standard specifications, the standard plans, the special provisions, the construction drawings nor shall they have any bearing whatsoever on the interpretation of the other publications referenced therein.