

Waterworks District No. 42 Well Soundings

Well # 3

Well Depth:	192
Pump Setting:	147
Pump HP:	20

Date	Sounding	GPM	on/off
01/01/20	95	240	on
02/01/20	81	240	off
03/01/20	76	240	off
04/01/20	93	240	on
05/01/20	75	240	off
06/01/20	84	240	off
07/01/20	100	240	on
08/01/20	N/A	240	N/A
09/01/20	N/A	240	N/A
10/01/20	N/A	240	N/A
11/01/20	N/A	240	N/A
12/01/20	N/A	240	N/A
01/01/21	76	240	off
02/01/21	79	240	off
03/01/21	81	240	off
04/01/21	83	240	off
05/01/21	80	240	off
06/01/21	91	240	on
07/01/21	90	240	off
08/01/21	95	240	off
09/01/21	109	240	on
10/01/21	N/A	240	N/A
11/01/21	81	240	off
12/01/21	N/A	240	N/A
12/01/21	78	240	off
02/02/22	86	240	on
03/02/22	58	240	off
04/01/22	74	240	on
05/01/22	101	240	on
06/01/22	95	240	off
07/01/22	108	240	on
08/01/22	93	240	off
09/01/22	102	240	on
10/01/22	106	240	on
11/01/22	83	240	off
12/01/22	83	240	off
01/01/23	N/A	240	N/A
02/01/23	N/A	240	N/A
03/01/23	N/A	240	N/A
04/01/23	104	240	on
05/01/23	106	240	off
06/01/23	108	240	off
07/01/23	104	240	off
08/01/23	110	240	off
09/01/23	108	240	off
10/01/23	113	240	off
11/01/23	N/A	240	N/A
12/04/23	N/A	240	N/A
01/02/24	74	240	off
02/01/24	79	240	off
03/01/24	71	240	off
04/01/24	73	240	off
05/01/24	89	240	off
06/01/24	118	240	off
10/01/24	87	240	on
03/01/25	74	240	off
04/01/25	84	240	off
05/01/25	74	240	off
06/01/25	99	240	on
07/01/25	113	240	on
08/01/25	105	240	on
09/01/25	108	240	on

Well # 4

Well Depth:	182
Pump Setting:	140
Pump HP:	30

Date	Sounding	GPM	on/off
01/01/20	80	250	off
02/01/20	75	250	off
03/01/20	72	250	off
04/01/20	79	250	off
05/01/20	76	250	off
06/01/20	81	250	off
07/01/20	86	250	off
08/01/20	N/A	250	N/A
09/01/20	N/A	250	N/A
10/01/20	N/A	250	N/A
11/01/20	N/A	250	N/A
12/01/20	N/A	250	N/A
01/01/21	76	250	off
02/01/21	80	250	off
03/01/21	77	250	off
04/01/21	74	250	off
05/01/21	92	250	on
06/01/21	94	250	on
07/01/21	91	250	off
08/01/21	89	250	off
09/01/21	92	250	off
10/01/21	N/A	250	N/A
11/01/21	50	250	off
12/01/21	76	250	on
01/01/22	75	250	on
02/02/22	75	250	off
03/02/22	76	250	off
04/01/22	78	250	off
05/01/22	51	250	on
06/01/22	69	250	off
07/01/22	90	250	off
08/01/22	80	250	off
09/01/22	90	250	off
10/01/22	93	250	off
11/01/22	81	250	off
12/01/22	81	250	off
01/01/23	N/A	250	N/A
02/01/23	N/A	250	N/A
03/01/23	N/A	250	N/A
4/1/2023	88	250	off
05/01/23	85	250	off
06/01/23	87	250	off
07/01/23	89	250	off
08/01/23	94	250	off
09/01/23	92	250	off
10/01/23	96	250	off
11/01/23	N/A	250	N/A
12/4/2023	N/A	250	N/A
01/02/24	79	250	off
02/01/24	75	250	off
03/01/24	42	250	on
04/01/24	42	250	on
05/01/24	84	250	on
06/01/24	40	250	on
10/01/24	88	250	on
03/01/25	72	250	off
04/01/25	76	250	off
05/01/25	79	250	off
06/01/25	89	250	off
07/01/25	93	250	off
08/01/25	79	250	off
09/01/25	49	250	on

Well #5

Well Depth:	172
Pump Setting:	140
Pump HP:	20

Date	Sounding	GPM	on/off
01/01/20	72	250	off
02/01/20	80	250	off
03/01/20	77	250	off
04/01/20	75	250	off
05/01/20	95	250	on
06/01/20	80	250	off
07/01/20	79	250	off
08/01/20	N/A	250	N/A
09/01/20	N/A	250	N/A
10/01/20	N/A	250	N/A
11/01/20	N/A	250	N/A
12/01/20	N/A	250	N/A
01/01/21	60	250	off
02/01/21	69	250	off
03/01/21	79	250	off
04/01/21	90	250	off
05/01/21	85	250	off
06/01/21	81	250	off
07/01/21	81	250	off
08/01/21	100	250	on
09/01/21	85	250	off
10/01/21	N/A	250	N/A
11/01/21	72	250	off
12/01/21	72	250	off
01/01/22	70	250	off
02/02/22	72	250	off
03/02/22	81	250	off
04/01/22	83	250	off
05/01/22	94	250	on
06/01/22	82	250	off
07/01/22	104	250	on
08/01/22	83	250	off
09/01/22	92	250	off
10/01/22	89	250	off
11/01/22	76	250	off
12/01/22	75	250	off
01/01/23	N/A	250	N/A
02/01/23	N/A	250	N/A
03/01/23	N/A	250	N/A
4/1/2023	85	250	off
05/01/23	83	250	off
06/01/23	85	250	off
07/01/23	88	250	off
08/01/23	90	250	off
09/01/23	91	250	off
10/01/23	94	250	off
11/01/23	N/A	250	N/A
12/4/2023	N/A	250	N/A
01/02/24	87	250	on
02/01/24	71	250	on
03/01/24	71	250	off
04/01/24	78	250	off
05/01/24	82	250	off
06/01/24	82	250	off
10/01/24	109	250	on
03/01/25	68	250	off
04/01/25	101	250	on
05/01/25	88	250	off
06/01/25	103	250	on
07/01/25	84	250	off
08/01/25	81	250	off
09/01/25	80	250	off